

June 2017 Heatwave

Sunday 18th through Sunday 25th

Forced Outages

1. CT1-Lodi : Fire System Trip : No Fire Present :
Lost 2 hours Sunday 20 Minutes on Monday
2. Bids affected Tuesday, exceptionally dispatched
3. STIG: O-ring Failure : 20 Minutes Late

Other Issues

1. STIG : Fire System Alarm : No Fire Present, No Trips
2. CT1-ALA: Failed Hydraulic Coupling
3. CT1-ALA: Fire System Failure, should have tripped
4. Air Conditioners, Air Conditioners, Air Conditioners

Hours and Starts

	Hours	Starts
STIG	38	5
Turner	46	8
ALA1	37	8
ALA2	37	7

23% of annual allowance
in 1 week

Margins

Facility	Cost	MWHR	\$/MWHR
STIG	\$158,560	1,019	\$155.60
Turner	\$62,458	1,051	\$59.42
ALA1	\$154,393	1,155	\$133.67
ALA2	\$135,824	1,051	\$129.23
CT1 Totals	\$352,675	3,257	\$108.28